



Sacramento  
Area Flood  
Control  
Agency

**ADDENDUM NO. 1**  
**CONTRACT NO. 4105**  
**FOR CONSTRUCTION OF**  
**NATOMAS LEVEE IMPROVEMENT PROGRAM**  
**SACRAMENTO RIVER EAST LEVEE PHASE 1E (REACH 2) PRIVATE**  
**IRRIGATION FACILITY REHABILITATION PROJECT**

**SACRAMENTO COUNTY, CALIFORNIA**

**September 1, 2011**

**APPROVED BY: SAFCA**



Richard M. Johnson  
Executive Director

9/1/2011  
Date

**TO ALL PROSPECTIVE BIDDERS:**

All prospective bidders are hereby advised that the attached addendum includes amendments to the Contract Documents that were issued by SAFCA on August 23, 2011. The bidders are to review all of the amendments listed herein, and acknowledge receipt of this addendum in the appropriate section of the Proposal Sheet.

Office 916-874-7606  
Fax 916-874-8289

1007 - 7th Street, 7th Floor  
Sacramento, CA 95814-3407

## **AMENDMENTS TO CONTRACT DOCUMENTS**

### **NOTICE TO CONTRACTORS**

1. Revise the Bid Date to September 7, 2011

### **VOLUME 1, TABLE OF CONTENTS**

1. TABLE OF CONTENTS
  - A. Revise the Table of Contents “REFERENCES” section by adding the following reference:

**CONTRACTOR’S QUESTIONS**

### **VOLUME 1, REFERENCES**

1. REFERENCES
  - A. Revise the “REFERENCES” cover page by adding the following reference:

**CONTRACTOR’S QUESTIONS**

### **Attachments**

CONTRACTOR’S QUESTIONS

**CONTRACTOR'S QUESTIONS**  
 Sacramento River East Levee Phase 1E  
 SAFCA Contract No. 4105  
 Issued for Bid 8/23/2011  
 Addendum No. 1

QUESTION NUMBER	ORIGINAL CONTRACTOR QUESTION	RESPONSE
1	If the river water surface is above the concrete work, will we have to provide de-watering?	The work will be performed during a period when river levels are forecasted to be well below the concrete foundation. Should river levels rise to the concrete foundation subgrade level, the work would be delayed and dewatering will be added to the Contract as a change order if it is required.
2	Will there be an addendum to include a de-watering task in the bid?	There will not be an additional task added to the bid. The contractor shall bid the project based on the assumption that river levels will be below the concrete work. See Item 1 above.